


**ADDENDUM 001
REQUEST FOR BIDS
(Sectional Overhead Doors)
RFB # (D8PP-10040)**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Name: Andy McNeill Title: Intermediate Procurement Agent
Bidder/Offeror Signature	Department of Transportation 
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: November 19, 2009

QUESTIONS/CLARIFICATIONS

Question:

Is the track for the doors to be for Standard Lift (door rolls back horizontally) construction or for High Lift (door rolls vertically up wall above header) construction.

Answer:

The clearance in the building above the door header is minimal, so this door should have Standard Lift construction for the track systems.

Should you have any questions, please call me at 417-895-7645.

Thank you,

Andy McNeill, CPPB
Intermediate Procurement Agent